



CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ

Project ID : South Brunswick BOE #6431
PAS Project ID : P17-0448

Matrix : Drinking Water
Report Date : 02/16/17

Table with 12 columns: PAS Sample ID, Client ID, Analysis, Results, Units, DF, PQL, MDL, MCL, Method, Date Sampled, Date Analyzed. Contains 47 rows of data for various lead samples.

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

- PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
B = Compound found in blank and samples
E = Concentration exceeds calibration range
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Handwritten signature of Mark D. Feitelson

Mark D. Feitelson, Lab. Director



CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ

Project ID : South Brunswick BOE #6431
PAS Project ID : P17-0448

Matrix : Drinking Water
Report Date : 02/16/17

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P17-0448-48	SBBA-1-S-02A	Lead	1.73 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 07:22	2/6/17 11:12
P17-0448-49	SBBA-1-B-01A	Lead	1.73 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 07:24	2/6/17 11:16
P17-0448-50	SBBA-1-B-02A	Lead	0.749 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 07:25	2/6/17 11:21
P17-0448-51	SBBA-1-B-03A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 07:36	2/6/17 11:25
P17-0448-52	SBBA-1-B-04A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 07:38	2/6/17 11:29
P17-0448-53	SBBA-1-B-05A	Lead	0.503 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 07:41	2/6/17 11:42
P17-0448-54	SBBA-1-B-06A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 07:44	2/6/17 11:47
P17-0448-55	SBBA-1-B-07A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 07:40	2/6/17 11:51
P17-0448-56	SBBA-1-B-08A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 07:49	2/6/17 11:55
P17-0448-57	SBBA-1-B-09A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 07:47	2/6/17 12:00
P17-0448-58	SBBA-1-B-10A	Lead	2.71	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 07:50	2/6/17 12:04
P17-0448-59	SBBA-1-B-11A	Lead	1.24 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 07:51	2/6/17 12:08
P17-0448-60	SBBA-1-B-12A	Lead	0.994 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 07:53	2/6/17 12:13
P17-0448-61	SBBA-1-B-13A	Lead	1.73 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 07:54	2/6/17 12:17
P17-0448-62	SBBA-1-B-14A	Lead	1.73 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 07:57	2/6/17 12:34
P17-0448-63	SBBA-1-B-15A	Lead	0.994 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 07:59	2/6/17 12:47
P17-0448-64	SBBA-1-B-16A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 08:00	2/6/17 12:51
P17-0448-65	SBBA-1-B-17A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 08:01	2/6/17 12:55
P17-0448-66	SBBA-1-B-18A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 08:03	2/6/17 13:00
P17-0448-67	SBBA-1-B-19A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 08:05	2/6/17 13:04
P17-0448-68	SBBA-1-B-20A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 08:16	2/6/17 13:16
P17-0448-69	SBBA-1-B-21A	Lead	0.749 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 08:14	2/6/17 13:21
P17-0448-70	SBBA-1-B-22A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 08:17	2/6/17 13:25
P17-0448-71	SBBA-1-B-23A	Lead	1.24 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 08:18	2/6/17 13:29
P17-0448-72	SBBA-1-B-25A	Lead	30.7	ug/L	5	10.0	2.31	15.0 *	SM 3113 B	1/28/17 08:32	2/6/17 14:11
P17-0448-73	SBBA-1-B-26A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 08:10	2/6/17 13:38
P17-0448-74	SBBA-1-B-27A	Lead	7.37	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 08:11	2/6/17 13:42
P17-0448-75	SBBA-1-B-28A	Lead	0.994 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 08:13	2/6/17 13:46
P17-0448-76	SBBA-1-B-29A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 08:25	2/6/17 14:15
P17-0448-77	SBBA-1-B-30A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 08:26	2/6/17 14:20
P17-0448-78	SBBA-1-B-31A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 08:27	2/6/17 14:24
P17-0448-79	SBBA-1-B-32A	Lead	0.994 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 08:30	2/6/17 14:28
P17-0448-80	SBBA-1-B-33A	Lead	0.503 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 08:31	2/6/17 14:32
P17-0448-81	SBBA-1-B-34A	Lead	0.503 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 08:40	2/6/17 14:36
P17-0448-82	SBBA-1-S-03A	Lead	2.96	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 08:36	2/6/17 14:44
P17-0448-83	SBBA-1-S-04A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 08:37	2/6/17 15:06
P17-0448-84	SBBA-1-S-05A	Lead	0.749 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 07:17	2/6/17 15:10
P17-0448-85	SBBA-1-WC-01A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 07:18	2/6/17 15:14
P17-0448-86	SBBA-1-28-FBA	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 07:20	2/6/17 15:19
P17-0448-87	SBBCD-1-B-01A	Lead	0.994 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 09:16	2/6/17 15:23
P17-0448-88	SBBCD-1-B-02A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 09:17	2/6/17 15:27
P17-0448-89	SBBCD-1-B-03A	Lead	2.22	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 09:21	2/6/17 15:32
P17-0448-90	SBBCD-1-S-01A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 09:22	2/6/17 15:45
P17-0448-91	SBBCD-1-S-02A	Lead	1.48 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 09:24	2/6/17 15:49
P17-0448-92	SBBCD-1-S-03A	Lead	0.503 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 09:25	2/6/17 15:53
P17-0448-93	SBBCD-1-B-04A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 09:27	2/6/17 15:58
P17-0448-94	SBBCD-1-B-05A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 09:28	2/6/17 16:02

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
B = Compound found in blank and samples
E = Concentration exceeds calibration range
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director

**CERTIFICATE OF ANALYSIS**

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ

Project ID : South Brunswick BOE #6431

PAS Project ID : P17-0448

Matrix : Drinking Water

Report Date : 02/16/17

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P17-0448-95	SBBCD-1-B-06A	Lead	4.67	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 09:29	2/6/17 16:06
P17-0448-96	SBBCD-2-B-07A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 09:32	2/6/17 16:11
P17-0448-97	SBBCD-2-B-08A	Lead	0.503 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 09:33	2/6/17 16:15
P17-0448-98	SBBCD-2-S-04A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 09:35	2/6/17 16:19
P17-0448-99	SBBCD-1-WC-01A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 09:26	2/6/17 16:40
P17-0448-100	SBBCD-1-28-FBA	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/28/17 09:15	2/6/17 16:44

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit

MDL = Minimum Detection Limit

MCL = Maximum Contaminant Level

DF = Dilution Factor

ND = Analyzed for but not detected

B = Compound found in blank and samples

E = Concentration exceeds calibration range

J = Estimated result

* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director