



CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ

Project ID : South Brunswick BOE #6431
PAS Project ID : P17-0271

Matrix : Drinking Water
Report Date : 02/02/17

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P17-0271-01	SBA-3-S-02A	Lead	0.600 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 05:12	1/25/17 11:38
P17-0271-02	SBA-3-WC-03A	Lead	0.600 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 05:11	1/25/17 11:46
P17-0271-03	SBA-2-WC-02A	Lead	5.60	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 05:08	1/25/17 11:59
P17-0271-04	SBA-3-WC-04A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 05:13	1/25/17 12:12
P17-0271-05	SBA-3-CM-01A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 05:12	1/25/17 12:16
P17-0271-06	SBA-1-WC-01A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 05:06	1/25/17 12:20
P17-0271-07	SBA-2-S-01A	Lead	1.10 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 05:09	1/25/17 12:24
P17-0271-08	SBA-1-14-FBA	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 05:15	1/25/17 12:29
P17-0271-09	SBBGT-1-BF-01A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 04:56	1/25/17 12:33
P17-0271-10	SBBGT-1-S-01A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 04:53	1/25/17 12:37
P17-0271-11	SBBGT-1-WC-01A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 04:56	1/25/17 12:41
P17-0271-12	SBBGT-1-14-FBA	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 04:58	1/25/17 12:46
P17-0271-13	SBBC-1-B-05A	Lead	0.600 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 07:29	1/25/17 12:59
P17-0271-14	SBBC-1-B-06A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 07:31	1/25/17 13:03
P17-0271-15	SBBC-1-B-07A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 07:32	1/25/17 13:07
P17-0271-16	SBBC-1-B-08A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 07:33	1/25/17 13:12
P17-0271-17	SBBC-1-B-09A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 07:36	1/25/17 13:16
P17-0271-18	SBBC-1-B-10A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 07:37	1/25/17 13:21
P17-0271-19	SBBC-1-B-11A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 07:37	1/25/17 13:25
P17-0271-20	SBBC-1-B-12A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 07:38	1/25/17 13:29
P17-0271-21	SBBC-1-B-13A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 07:39	1/25/17 13:34
P17-0271-22	SBBC-1-B-14A	Lead	2.10	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 07:40	1/25/17 13:51
P17-0271-23	SBBC-1-WC-04A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 07:42	1/25/17 14:04
P17-0271-24	SBBC-1-WC-05A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 07:42	1/25/17 14:08
P17-0271-25	SBBC-1-B-15A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 07:43	1/25/17 14:12
P17-0271-26	SBBC-1-B-16A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 07:44	1/25/17 14:16
P17-0271-27	SBBC-1-B-17A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 07:45	1/25/17 14:20
P17-0271-28	SBBC-1-B-18A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 07:48	1/25/17 14:47
P17-0271-29	SBBC-1-B-19A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 07:49	1/25/17 14:51
P17-0271-30	SBBC-1-B-20A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 07:50	1/25/17 14:55
P17-0271-31	SBBC-1-B-21A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 07:50	1/25/17 15:00
P17-0271-32	SBBC-1-B-22A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 07:51	1/25/17 15:04
P17-0271-33	SBBC-1-B-23A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 07:52	1/25/17 15:08
P17-0271-34	SBBC-1-B-24A	Lead	0.600 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 07:54	1/25/17 15:13
P17-0271-35	SBBC-1-B-25A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 07:54	1/25/17 15:31
P17-0271-36	SBBC-1-B-26A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 07:56	1/25/17 15:35
P17-0271-37	SBBC-1-B-27A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 07:57	1/25/17 15:40
P17-0271-38	SBBC-1-B-28A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 07:59	1/25/17 15:44
P17-0271-39	SBBC-1-B-29A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 08:02	1/25/17 15:48
P17-0271-40	SBBC-1-WC-06A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 08:02	1/25/17 15:52
P17-0271-41	SBBC-1-WC-07A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 08:04	1/27/17 11:03
P17-0271-42	SBBC-1-WC-08A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 08:05	1/27/17 11:12
P17-0271-43	SBBC-S-08A	Lead	0.815 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 08:05	1/27/17 11:24
P17-0271-44	SBBC-1-17-FBA	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 08:10	1/27/17 11:47
P17-0271-45	SBBC-1-WC-01A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 07:07	1/27/17 11:51
P17-0271-46	SBBC-1-WC-02A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 07:08	1/27/17 11:55
P17-0271-47	SBBC-1-PF-01A	Lead	5.00	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 07:10	1/27/17 12:00

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

- PQL = Practical Quantitation Limit
- MDL = Minimum Detection Limit
- MCL = Maximum Contaminant Level
- DF = Dilution Factor
- ND = Analyzed for but not detected
- B = Compound found in blank and samples
- E = Concentration exceeds calibration range
- J = Estimated result
- * Federal Action Level

All samples are analyzed in accordance with New Jersey Department of Environmental Protection Protocol

Mark D. Feitelson, Lab. Director



CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ

Project ID : South Brunswick BOE #6431
PAS Project ID : P17-0271

Matrix : Drinking Water
Report Date : 02/02/17

Table with 12 columns: PAS Sample ID, Client ID, Analysis, Results, Units, DF, PQL, MDL, MCL, Method, Date Sampled, Date Analyzed. Contains 40 rows of test data for Lead.

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

- PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
B = Compound found in blank and samples
E = Concentration exceeds calibration range
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Handwritten signature of Mark D. Feitelson

Mark D. Feitelson, Lab. Director



CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ

Project ID : South Brunswick BOE #6431
PAS Project ID : P17-0271

Matrix : Drinking Water
Report Date : 02/02/17

Table with 12 columns: PAS Sample ID, Client ID, Analysis, Results, Units, DF, PQL, MDL, MCL, Method, Date Sampled, Date Analyzed. Contains 141 rows of analytical data for Lead.

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

- PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
B = Compound found in blank and samples
E = Concentration exceeds calibration range
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Handwritten signature of Mark D. Feitelson

Mark D. Feitelson, Lab. Director



CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ

Project ID : South Brunswick BOE #6431

PAS Project ID : P17-0271

Matrix : Drinking Water

Report Date : 02/02/17

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P17-0271-142	SBIF-1-B-28A	Lead	3.54	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 09:42	1/27/17 14:59
P17-0271-143	SBIF-1-S-09A	Lead	2.25	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 09:45	1/27/17 15:12
P17-0271-144	SBIF-1-B-29A	Lead	19.6	ug/L	2	4.00	0.924	15.0 *	SM 3113 B	1/14/17 09:45	1/27/17 15:41
P17-0271-145	SBIF-1-17-FBA	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/14/17 09:48	1/27/17 15:20

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit

MDL = Minimum Detection Limit

MCL = Maximum Contaminant Level

DF = Dilution Factor

ND = Analyzed for but not detected

B = Compound found in blank and samples

E = Concentration exceeds calibration range

J = Estimated result

* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director