



## CERTIFICATE OF ANALYSIS

**Customer :** Garden State Environmental  
555 South Broad Street, Suite K  
Glen Rock, NJ 07452

**Project ID :** South Brunswick BOE, Monmouth Junction  
**PAS Project ID :** P17-2240

**Matrix :** Drinking Water  
**Report Date :** 5/22/2017

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P17-2240-01	SMBJ-1-B-14A	Lead	1.61 J	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	5/8/17 08:12	5/17/17 09:53
P17-2240-02	SMBJ-1-B-14B	Lead	ND	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	5/8/17 08:13	5/17/17 09:56
P17-2240-03	SMBJ-5-8-FBA	Lead	ND	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	5/8/17 08:10	5/17/17 10:08

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit  
MDL = Minimum Detection Limit  
MCL = Maximum Contaminant Level  
DF = Dilution Factor  
ND = Analyzed for but not detected  
J = Estimated result  
\* Federal Action Level

All samples are analyzed in accordance with  
New Jersey Department of Environmental  
Protection Protocol

Mark D. Feitelson, Lab. Director