



CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ 07452

Project ID : South Brunswick #6431
PAS Project ID : P17-1644

Matrix : Drinking Water
Report Date : 4/26/2017

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P17-1644-01	SBNC-1-B-10A	Lead	14.7	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/13/17 05:06	4/19/17 12:27
P17-1644-02	SBNC-1-B-10B	Lead	2.25	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/13/17 05:06	4/19/17 12:31
P17-1644-03	SBNC-4-13-FBA	Lead	ND	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/13/17 05:08	4/19/17 12:36
P17-1644-04	SBIF-1-WC-09A	Lead	ND	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/13/17 05:23	4/19/17 13:08
P17-1644-05	SBIF-1-WC-09B	Lead	ND	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/13/17 05:38	4/19/17 13:13
P17-1644-06	SBIF-4-13-FBA	Lead	ND	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/13/17 05:30	4/19/17 13:17
P17-1644-07	SBGB-1-B-11A	Lead	2.25	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/13/17 06:04	4/19/17 13:21
P17-1644-08	SBGB-1-B-11B	Lead	ND	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/13/17 06:05	4/19/17 13:25
P17-1644-09	SBGB-4-13-FBA	Lead	ND	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/13/17 06:07	4/19/17 13:30
P17-1644-10	SBCON-1-S-10A	Lead	2.80	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/13/17 06:30	4/19/17 14:00
P17-1644-11	SBCON-1-S-10B	Lead	ND	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/13/17 06:31	4/19/17 14:04
P17-1644-12	SBCON-4-13-FBA	Lead	ND	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/13/17 06:33	4/19/17 14:09
P17-1644-13	SBSC-1-B-104A	Lead	8.04	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/13/17 06:50	4/19/17 14:13
P17-1644-14	SBSC-1-B-104B	Lead	0.593 J	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/13/17 06:51	4/19/17 14:17
P17-1644-15	SBSC-1-B-200A	Lead	1.42 J	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/13/17 06:56	4/19/17 14:30
P17-1644-16	SBSC-1-B-200B	Lead	ND	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/13/17 06:56	4/19/17 14:55
P17-1644-17	SBSC-1-B-10A	Lead	15.8	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/13/17 07:00	4/19/17 14:59
P17-1644-18	SBSC-1-B-10B	Lead	1.42 J	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/13/17 07:01	4/19/17 15:04
P17-1644-19	SBSC-4-13-FBA	Lead	ND	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/13/17 07:04	4/19/17 15:08
P17-1644-20	SBHS -1 B-06A	Lead	ND	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/13/17 07:14	4/19/17 15:12
P17-1644-21	SBHS -1 B-06B	Lead	ND	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/13/17 07:15	4/19/17 12:17
P17-1644-22	SBHS -4-13-FBA	Lead	ND	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/13/17 07:17	4/19/17 15:53

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director